

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No. 183

Date : 02.02.2023

It is certified that an inspection team headed by Amiruddin Ansari
J.B. P.H. section Islampur (Name of Officers
with designation) from P.H.D. Division Hilsa (Name of
Department/Office) inspected the Shemford futuristic school
Islampur (Name & Address of
the School) on _____ and found that the Shemford futuristic school
Islampur (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 36 months.

Signature with Seal : [Signature]

Name : Rajesh Kumar **Executive Engineer**
P.H. Division, HILSA

Designation : Executive Engineer

To

Shemford futuristic school
Islampur

(Name & Address of the Institution)

Government of Bihar
Public Health Engineering Department
Water Quality Report

P.H.Division, Hilsa

Sample Test Date:- 03.01.2023

Scheme Name :-SHEMFORD FUTURISTIC SCHOOL

Ward No:-05

Block:- ISLAMPUR

Panchayat:-ISLAMPUR

Parameter	RW_ph	RW_EC	RW_TDS	RW_TH	RW_CI	RW_Alk	RW_Ca	RW_Mg	RW_F	Turbidity	RW_Tcoli
Unit+B6:L10	-	ymho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/ltr	MPN/100ml	MPN/100ml
Desirable Limit*	6.5-8.5	-	500	200	250	200	75	30	1	1	-
Permissible Limit* in absence of alternate source	NR	-	2000	600	1000	600	200	100	1.5	5	-
Measured Value	8.26	400	260	200	80	280.00	48.09	19.44	0.40	0.20	0.00

Nargesh Vimal
02/02/2023
Chemist
P.H.Division, Hilsa